

# VOC Content Test Certificate

Tuesday November 15<sup>th</sup>, 2011

Manufacturer: Knauf Plasterboard (31 Military Rd, Matraville NSW 2036)

Date Tested: \*October 2008 (Tested by FORAY Laboratories – NATA Accreditation 1231)

^April 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<p align="center"><b>Specification</b></p> <p><b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b></p>	<p><b>MastaSmooth*, MastaRapid* MastaLongset*, MastaLite* MastaFinish*, MastaCove 75* MastaCove 45*, MastaBond*, MastaBlock* MastaBase*, MastaFix 20* DecoMachine^, MastaGlide^, MastaLite^</b></p>
<p>Dry Wall and Panel Adhesive</p> <p>50 grams per Litre as VOC content per material</p>	<p><b>&lt;50 grams per Litre as VOC content per material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Anne Saletti  
BNanotech/BSc(Hons)  
Consultant

CV111109